

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
340490410042003	0001	Main Building	12/16/2017	08:04 AM	E. Pena	BJS-1A	Nurse's Office	S - Sink	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:05 AM	E. Pena	BJS-1B	Nurse's Office	S - Sink	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:06 AM	E. Pena	BJS-2A	Nurse's Bathroom	S - Sink	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	64.0 ppb	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:07 AM	E. Pena	BJS-2B	Nurse's Bathroom	S - Sink	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	7.57 ppb	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:08 AM	E. Pena	BJWF-3A	Hallway Across Mechanical Room 101	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:09 AM	E. Pena	BJWF-3B	Hallway Across Mechanical Room 101	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:10 AM	E. Pena	BJS-4A	Teacher's Lounge	S - Sink	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:11 AM	E. Pena	BJS-4B	Teacher's Lounge	S - Sink	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:13 AM	E. Pena	BJS-5A	Classroom 100	S - Sink	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:14 AM	E. Pena	BJS-5B	Classroom 100	S - Sink	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:15 AM	E. Pena	BJS-6A	Classroom 200	S - Sink	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:16 AM	E. Pena	BJS-6B	Classroom 200	S - Sink	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	3.56 ppb	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:19 AM	E. Pena	BJWF-7A	Hallway Across Janitorial Room 216	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:20 AM	E. Pena	BJWF-7B	Hallway Across Janitorial Room 216	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:21 AM	E. Pena	BJKS-8A	Kitchen South Sink	S - Sink	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	2.35 ppb	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:22 AM	E. Pena	BJKS-8B	Kitchen South Sink	S - Sink	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:23 AM	E. Pena	BJKS-9A	Kitchen North Sink	S - Sink	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	13.7 ppb	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:24 AM	E. Pena	BJKS-9B	Kitchen North Sink	S - Sink	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:25 AM	E. Pena	BJWF-10A	Hallway Across Learning Center Room 302 - North	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:26 AM	E. Pena	BJWF-10B	Hallway Across Learning Center Room 302 - North	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:27 AM	E. Pena	BJWF-11A	Hallway Across Learning Center Room 302 - South	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:28 AM	E. Pena	BJWF-11B	Hallway Across Learning Center Room 302 - South	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:29 AM	E. Pena	BJWF-12A	Hallway Across Room 405 - West	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:30 AM	E. Pena	BJWF-12B	Hallway Across Room 405 - West	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:31 AM	E. Pena	BJWF-13A	Hallway Across Room 405 - East	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:32 AM	E. Pena	BJWF-13B	Hallway Across Room 405 - East	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:33 AM	E. Pena	BJWF-14A	Hallway Across Room 408 - West	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:34 AM	E. Pena	BJWF-14B	Hallway Across Room 408 - West	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:35 AM	E. Pena	BJWF-15A	Hallway Across Room 408 - East	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:36 AM	E. Pena	BJWF-15B	Hallway Across Room 408 - East	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:38 AM	E. Pena	BJWF-16A	Hallway Across Room 410 - West	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:39 AM	E. Pena	BJWF-16B	Hallway Across Room 410 - West	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:40 AM	E. Pena	BJWF-17A	Hallway Across Room 410 - East	inking Fountain	12/15/2017	06:00 PM	First Draw	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	
340490410042003	0001	Main Building	12/16/2017	08:41 AM	E. Pena	BJWF-17B	Hallway Across Room 410 - East	inking Fountain	12/15/2017	06:00 PM	Flush	250	Prairie Analytical	EPA 200.8	ND	2.00 ppb	